#### **LAYOUT & MATERIALS NOTES**

- 1. ALL ACCESSIBLE CURB CUTS SHALL BE CONSTRUCTED TO MEET A.D.A. AND M.A.A.B. REQUIREMENTS.
- AT AREAS OF VERTICAL GRANITE CURB, TRANSITIONAL VERTICAL GRANITE CURB AND FLUSH GRANITE CURB SHALL BE PROVIDED AS NECESSARY. SEE NOTE 3 BELOW.
- 2. ACCESSIBLE PARKING SPACES AND ACCESS AISLES SHALL NOT EXCEED A SLOPE OF 1:50 (2%) IN ANY DIRECTION.
- 3. WALKWAY GRADES SHALL NOT HAVE SLOPES IN EXCESS OF 1:20 (5%) OR CROSS SLOPES IN EXCESS OF 1:50 (2%), UNLESS OTHERWISE NOTED.
- 4. WALK GRADIENTS AND CROSS SLOPES SHOWN ON THE GRADING PLANS ARE WITHIN, OR LESS THAN, THE REQUIREMENTS OF THE MASSACHUSETTS ARCHITECTURAL ACCESS BOARD'S (MAAB) REGULATIONS. IT IS THE CONTRACTOR'S RESPONSIBILITY TO CONSTRUCT THE WORK SO THAT IT IS COMPLIANT WITH ALL REQUIRED REGULATIONS. NOTE THAT THE MAXIMUM GRADIENTS WITHIN THE REGULATIONS DO NOT RECOGNIZE "CONSTRUCTION TOLERANCES." EXCEEDING THE MAXIMUM GRADIENTS IN THE REGULATIONS IS ENTIRELY AT THE CONTRACTOR'S RISK. THE CONTRACTOR SHALL VERIFY IN WRITING THAT ALL WALKS HAVE BEEN CONSTRUCTED IN COMPLIANCE WITH THE MAAB'S REGULATIONS.
- 5. CURB RADII AND DIMENSIONS SHOWN ARE AT THE FACE OF CURB.
- 6. LAYOUT SHOWN HEREON IS BASED UPON THE EXISTING CONDITIONS SURVEY PLAN CONTAINED IN THIS SET OF DRAWINGS. SURVEYOR OF RECORD SHALL BE CONTACTED PRIOR TO COMMENCEMENT OF ANY SITE WORK TO ESTABLISH SURVEY CONTROL FOR LAYOUT PURPOSES.
- 7. ALL ACCESSIBLE PARKING SPACES SHALL HAVE SIGNAGE AND MARKINGS COMPLIANT WITH MAAB REGULATIONS.
- 8. ROAD AND PARKING STRIPING SHALL BE STANDARD 4-INCH WIDE STRIPING AND MEET MUTCD STANDARDS.

## **PARKING DATA**

REQUIRED:

RETAIL SPACE - 8,870 SF OF GROSS FLOOR AREA MAXIMUM OF ONE (1) SPACE PER 200 SF OF GROSS FLOOR AREA 8,870 SF / 200 SF X 1 = 45 SPACES REQUIRED (MAXIMUM) MINIMUM OF ONE (1) SPACE PER 500 SF OF GROSS FLOOR AREA 8,870 SF / 500 SF X 1 = 18 SPACES REQUIRED (MINIMUM)TOTAL REQUIRED: 18-45 SPACES FOR RETAIL SPACE

RESIDENTIAL FLOORS (16 UNITS) TWO (2) SPACES FOR EVERY UNIT 16 UNITS X 2 = 32 SPACES REQUIRED TOTAL REQUIRED: 32 SPACES FOR RESIDENTIAL

TOTAL REQUIRED: 50-77 SPACES FOR BOTH USES

TOTAL SHOWN: 50 (18 SURFACE + 32 GARAGE)

ACCESSIBLE PARKING: SPACES REQUIRED = 3 INCLUDING 1 VAN ACCESSIBLE SPACES PROPOSED = 3 TOTAL (2 IN THE GARAGE AND

1 VAN ACCESSIBLE IN THE PARKING LOT)

**CUT TYPE 1** 

MAIN (ROUTE 1A) STREET

# **LEGEND**

(SEE EXISTING CONDITIONS PLAN FOR EXISTING CONDITIONS SYMBOLS AND ABBREVIATIONS)

PROPOSED LANDSCAPED AREA

PROPOSED FIRST FLOOR ELEVATION

PROPOSED GARAGE FLOOR ELEVATION

PROPOSED PRECAST CONCRETE CURB

VGC PROPOSED VERTICAL GRANITE CURB

FGC PROPOSED FLUSH GRANITE CURB PROPOSED TRANSITIONAL GRANITE CURB

CB PROPOSED CATCH BASIN

PROPOSED DRAIN MANHOLE ocs

PROPOSED OUTLET CONTROL STRUCTURE STU PROPOSED STORMWATER TREATMENT UNIT

PROPOSED TOP OF WALL ELEVATION

PROPOSED LANDSCAPED AREA PROPOSED CURB RADIUS

# N26°51'04"E 94.84(C) 94.85'(R) PCC NO PARKING ZONE (TURN AROUND AREA) - 10' x 18' CONCRETE DUMPSTER PAD WITH CHAIN LINK PRIVACY FENCE **ENCLOSURE AND ACCESS GATES** BITUMINOUS CONCRETE PAVEMENT (TYP) FIRST FLOOR RETAIL SPACE -4.0' TO FACE OF CURB INSTALL ACCESSIBLE -PARKING SIGN ACCESSIBLE CURB — CUT TYPE 2 BITUMINOUS 18.5 TYP CONCRETE PAVEMENT (TYP) PROPOSED BUILDING ROOF LINE=232.0<sub>/8"</sub> F.F.=197.0<sub>/6.5</sub> G.F.=187.0 -3.0<sup>11</sup>TO FACE OF WALL -PROPOSED RETAINING WALL T.O.W.=198.5 -6.0' TO SUBSURFACE GARAGE 2ND & 3RD FIRST FLOOR RETAIL SPACE GARAGE DOOR — -EXISTING BILLBOARD TO REMAIN RETAINING WALLS— BITUMINOUS CONCRETE —ACCESSIBLE CURB CUT TYPE 1 -4' WIDE CONCRETE 123.81'(R) 537.03' TO P.C. AT NORFOLK ST. (R) **MATCH TO EXISTING-**MATCH TO EXISTING ACCESSIBLE CURB

ACCESSIBLE CURB CUT TYPE 1

XX — ACCESSIBLE CURB CUT TYPE 1

--- REPLACE EXISTING BITUMINOUS SIDEWALK

## **ZONING CHART**

	REQUIRED	PROPOSED
LOT AREA	15,000 SF	32,488 SF
FRONT SETBACK	15 FT (MIN) 25 FT (MAX)	25.0 FT
SIDE SETBACK	6 FT	6.0 FT (NORTH 6.2 FT (SOUTH
REAR SETBACK	20 FT	44.0 FT
BUILDING HEIGHT	40 FT	35.31 FT (SEE SHEET C-2
STORIES	3 (MAX)	3 STORIES
LOT COVERAGE BY STRUCTURE	40% (12,995 SF)	34.9% (11,322 SF)
LOT COVERAGE BY STRUCTURE & IMPERVIOUS	70% (22,741 SF)	69.8% (22,697 SF)

## **■ DGT Associates** Surveying & Engineering

Framingham **Boston** • Worcester

1071 Worcester Road Framingham, MA 01701 508-879-0030

www.DGTassociates.com

#### **ARCHITECT**

NUNES TRABUCCO ARCHITECTS 109 HIGHLAND AVENUE NEEDHAM, MA 02494 781-455-9980

#### LANDSCAPE ARCHITECT


MICHAEL D'ANGELO LANDSCAPE ARCHITECTURE LLC 732 EAST BROADWAY, SUITE #3 BOSTON, MA 02127 203-592-4788

PREPARED FOR / APPLICANT:

SAYED HALABI

ISSUED FOR:

## PERMITTING PURPOSES



DATE: **APRIL 15, 2020** 

SCALE: 1" = 20'

DESIGNED: DRAFTED: CHECKED:

PROJECT TITLE:

**PERMIT SITE PLAN** 


1363 - 1365 MAIN STREET **WALPOLE, MASSACHUSETTS 02081** 

SHEET TITLE:

SITE LAYOUT AND **MATERIALS PLAN** 

1 OF 10 PROJECT NO. 25551

**CE-01** 




## **DRAINAGE NOTES**

- FOR ROOF DRAINS, SEE PLUMBING PLANS. ROOF DRAINS EXITING THE BUILDING TO 10 FEET FROM THE BUILDING ARE BY THE PLUMBING CONTRACTOR. SITE CONTRACTOR TO COORDINATE WITH THE PLUMBER.
- 2. FOR FOUNDATIONS DRAINS, UNDER SLAB DRAIN CONNECTIONS AND CLEANOUT DETAILS, SEE STRUCTURAL PLANS.
- UNLESS OTHERWISE NOTED ON THE PLANS, ALL DRAINAGE PIPE SHALL BE HDPE AND SHALL BE HEAVY DUTY CORRUGATED SMOOTH INTERIOR WALL PIPE (HDPE) OR APPROVED EQUAL.
- STORMATER MANAGEMENT STRUCTURES/MANHOLES TO REMAIN:
   ADJUST FRAMES AND COVERS TO FINISHED GRADE AS NECESSARY.
  WHEN ADJUSTING UP LESS THAN 18", USE BRICK AND MORTAR TO
  RAISE FRAME AND COVER. WHEN ADJUSTING GREATER THAN 18", USE
  PRECAST CONCRETE RING ALONG WITH BRICK AND MORTAR TO BRING
  TO GRADE
- GRADE.
   ALL WORK PER THE TOWN OF WALPOLE DPW REQUIREMENTS.
- 5. ALL UTILITIES NOTED AS "TO BE REMOVED/ABANDONED": EXISTING UTILITIES TO BE REMOVED/ABANDONED WHERE THEY INTERFERE WITH NEW CONSTRUCTION CANNOT BE ABANDONED IN PLACE, UNLESS OTHERWISE NOTED, AND SHALL BE REMOVED. OTHER UTILITIES SHOWN TO BE REMOVED/ABANDONED MAY BE CUT, CAPPED AND FILLED WITH FLOWABLE FILL AND ABANDONED IN PLACE. UTILITIES ABANDONED IN PLACE SHALL BE LOCATED, NOTED AND SHOWN ON THE AS—BUILT PLANS.
- 6. CONTRACTOR TO COORDINATE ELECTRIC / TELECOMM DUCT BANK LOCATIONS AND ELEVATIONS TO AVOID CONFLICT WITH DRAIN LINES AND STRUCTURES.

## **LEGEND**

(SEE EXISTING CONDITIONS PLAN FOR EXISTING CONDITIONS SYMBOLS AND ABBREVIATIONS)

——D——	PROPOSED DRAIN LINE
——RD——	PROPOSED ROOF DRAIN
——FD——	PROPOSED FOUNDATION DRAIN
—— W ——	PROPOSED WATER LINE
——FP——	PROPOSED FIRE PROTECTION SERVICE LINE
s	PROPOSED SEWER LINE
——FM——	PROPOSED DRAIN LINE FORCE MAIN
— G —	PROPOSED GAS LINE
$\sim\sim$	EXISTING UTILITY TO BE REMOVED/ABANDONED (SEE NOTES)
DMH(D)	PROPOSED DRAIN MANHOLE
STUD	PROPOSED STORMWATER TREATMENT UNIT
СВ	PROPOSED DEEP SUMP CATCH BASIN
OCS	PROPOSED OUTLET CONTROL STRUCTURE
WG 📉	PROPOSED WATER GATE VALVE





Framingham
Boston • Worcester

1071 Worcester Road Framingham, MA 01701 508-879-0030

www.DGTassociates.com

#### ARCHITECT

NUNES TRABUCCO ARCHITECTS 109 HIGHLAND AVENUE NEEDHAM, MA 02494 781-455-9980

#### LANDSCAPE ARCHITECT


MICHAEL D'ANGELO LANDSCAPE ARCHITECTURE LLC 732 EAST BROADWAY, SUITE #3 BOSTON, MA 02127 203-592-4788

PREPARED FOR / APPLICANT:

SAYED HALABI

ISSUED FOR:

## PERMITTING PURPOSES



DATE: **APRIL 15, 2020** 

SCALE: 1" = 20'

DESIGNED: DRAFTED: CHECKED: KMR KMR FWK

PROJECT TITLE:

# PERMIT SITE PLAN

1363 - 1365 MAIN STREET WALPOLE, MASSACHUSETTS 02081

SHEET TITLE:

GRADING AND DRAINAGE PLAN

SHEET:
2 OF 10

PROJECT NO.:

**CE-02** 



## SITE UTILITY NOTES

- ALL UTILITY INSTALLATION TO BE IN FULL COMPLIANCE WITH THE TOWN OF WALPOLE DPW REQUIREMENTS.
- 2. REFER TO PLUMBING DRAWINGS FOR ADDITIONAL SEWER, WATER AND GAS INFORMATION.
- 3. ALL WATER MAINS AND SERVICES TO HAVE A MINIMUM COVER OF 5'-0".
- 4. FOR SIAMESE FIRE CONNECTIONS AND FIRE SERVICE CONNECTIONS, SEE FIRE PROTECTION PLANS.
- 5. SEWER SERVICE INSTALLATION:
- CONTRACTOR IS TO PERFORM ALL SEWER INSTALLATION WORK SUCH THAT THERE IS NO DISRUPTION IN SERVICE TO THE EXISTING FACILITIES.

   ALL EXISTING SEWER CONNECTIONS AND/OR COMPONENTS TO BE ABANDONED SHALL BE PROPERLY CAPPED AND PLUGGED IN

ACCORDANCE WITH THE TOWN OF WALPOLE DPW REQUIREMENTS.

- 6. ALL UTILITIES NOTED AS "TO BE REMOVED/ABANDONED": EXISTING UTILITIES TO BE REMOVED/ABANDONED WHERE THEY INTERFERE WITH NEW CONSTRUCTION CANNOT BE ABANDONED IN PLACE AND SHALL BE REMOVED. OTHER UTILITIES SHOWN TO BE REMOVED/ABANDONED MAY BE CUT, CAPPED AND FILLED WITH FLOWABLE FILL AND ABANDONED IN PLACE. UTILITIES ABANDONED IN PLACE SHALL BE LOCATED, NOTED AND SHOWN ON THE
- 7. CONTRACTOR TO COORDINATE ELECTRIC / TELECOMM DUCT BANK LOCATIONS AND ELEVATIONS TO AVOID CONFLICT WITH PROPOSED SEWER, WATER AND GAS LINES AND STRUCTURES AND ALL EXISTING UTILITIES.
- 8. AT THIS TIME, THE PIPE SIZES FOR THE WATER SERVICE LINES AND SEWER SERVICE LINE ARE SHOWN AS APPROXIMATE. FINAL PIPE SIZES TO BE COORDINATED WITH THE PLUMBING ENGINEER FOR CONSTRUCTION

# LEGEND

HYD 🔷


HDPE

(SEE EXISTING CONDITIONS PLAN FOR EXISTING CONDITIONS SYMBOLS AND ABBREVIATIONS)

PROPOSED DRAIN LINE PROPOSED ROOF DRAIN PROPOSED FOUNDATION DRAIN PROPOSED WATER LINE PROPOSED FIRE PROTECTION SERVICE LINE PROPOSED SEWER LINE ——FM—— PROPOSED SEWER FORCE MAIN LINE — G — PROPOSED GAS LINE  $\sim\sim\sim$ EXISTING UTILITY TO BE REMOVED/ABANDONED (SEE NOTES) PROPOSED DRAIN MANHOLE STU(D) PROPOSED STORMWATER TREATMENT UNIT CB 🏢 PROPOSED DEEP SUMP CATCH BASIN PROPOSED ROOF DRAIN ocs PROPOSED OUTLET CONTROL STRUCTURE SMHS PROPOSED SEWER MANHOLE WG 🛏 PROPOSED WATER GATE VALVE

PROPOSED FIRE HYDRANT

HIGH DENSITY POLYETHYLENE





Framingham Boston • Worcester

1071 Worcester Road Framingham, MA 01701 508-879-0030

www.DGTassociates.com

#### ARCHITECT

NUNES TRABUCCO ARCHITECTS 109 HIGHLAND AVENUE NEEDHAM, MA 02494 781-455-9980

#### LANDSCAPE ARCHITECT


MICHAEL D'ANGELO LANDSCAPE ARCHITECTURE LLC 732 EAST BROADWAY, SUITE #3 BOSTON, MA 02127 203-592-4788

PREPARED FOR / APPLICANT:

SAYED HALABI

ISSUED FOR:

## PERMITTING PURPOSES



DATE: **APRIL 15, 2020** 

SCALE: 1" = 20'

DESIGNED: DRAFTED: CHECKED: KMR KMR FWK

PROJECT TITLE:

# PERMIT SITE PLAN

1363 - 1365 MAIN STREET WALPOLE, MASSACHUSETTS 02081

SHEET TITLE:

SITE UTILITIES PLAN


SHEET: **3 OF 10**PROJECT NO.: **25551** 

SCALE: 1" = 20'

**CE-03** 

## **GENERAL DEMOLITION NOTES**

- 1. ALL UTILITY INSTALLATION AND REMOVALS TO BE IN FULL COMPLIANCE WITH THE TOWN OF WALPOLE DPW STANDARDS AND REQUIREMENTS. WHERE ANY WORK SHOWN ON THESE PLANS CONFLICTS WITH THOSE STANDARDS AND REQUIREMENTS THE TOWN OF WALPOLE STANDARDS WILL CONTROL.
- 2. LOCATION OF UNDERGROUND UTILITIES SHOWN HEREON ARE BASED ON FIELD LOCATION OF VISIBLE STRUCTURES SUCH AS CATCH BASINS, MANHOLES, WATER GATES, ETC., AND COMPILING INFORMATION FROM PLANS SUPPLIED BY VARIOUS UTILITY COMPANIES AND GOVERNMENT AGENCIES. THE LOCATION SHOWN SHALL BE CONSIDERED APPROXIMATE. BEFORE CONSTRUCTION, THE LOCATION OF UNDERGROUND UTILITIES SHALL BE VERIFIED BY THE CONTRACTOR AND REPORT TO THE ARCHITECT PRIOR TO BEGINNING WORK ANY DISCREPANCIES BETWEEN THE PLANS AND THE ACTUAL SITE CONDITIONS. IN ACCORDANCE WITH CH. 82, SEC. 40 AS AMENDED, ALL UTILITY COMPANIES AND APPLICABLE GOVERNMENT AGENCIES MUST BE CONTACTED. CONTACT "DIG-SAFE" AT 811.
- 3. CONTRACTOR SHALL OBTAIN ANY REQUIRED TRENCHING AND ROAD OPENING PERMIT FROM THE TOWN OF WALPOLE PUBLIC WORKS DEPARTMENT AND MASS DOT AS NECESSARY FOR ANY WORK WITHIN THE PUBLIC RIGHT OF WAY.
- 4. ALL TRENCH EXCAVATION CONTRACTORS SHALL COMPLY WITH MASSACHUSETTS GENERAL LAWS CHAPTER 82A, TRENCH EXCAVATION SAFETY REQUIREMENTS, TO PROTECT THE GENERAL PUBLIC FROM UNAUTHORIZED ACCESS TO UNATTENDED TRENCHES. A TRENCH EXCAVATION PERMIT IS REQUIRED. THIS APPLIES TO ALL TRENCHES ON PUBLIC AND PRIVATE PROPERTY.
- 5. SAWCUT AND PATCH OF PAVEMENT WITHIN THE STATE ROAD RIGHT OF WAY SHALL BE PERFORMED PER THE MASS DOT STANDARDS.
- 6. ALL UTILITY TRENCHES WITHIN THE RIGHT-OF-WAY SHALL BE BACKFILLED IN ACCORDANCE WITH THE TOWN OF WALPOLE DPW STANDARDS AND MASS DOT STANDARDS.
- 7. FOR ALL DEMOLITION OF EXISTING LANDSCAPE AREAS AND EXISTING TREES, SEE THE LANDSCAPE PLANS.
- 8. SEE SHEET CE-05 FOR EROSION AND SEDIMENT CONTROL NOTES.



## **LEGEND**


(SEE EXISTING CONDITIONS PLAN FOR EXISTING CONDITIONS SYMBOLS AND ABBREVIATIONS)

T.B.R.

EXISTING UTILITY TO BE REMOVED/ABANDONED (SEE NOTES)

TO BE REMOVED

20 0 10 20 40 SCALE: 1" = 20'



Framingham
Boston • Worcester

1071 Worcester Road Framingham, MA 01701 508-879-0030

www.DGTassociates.com

#### **ARCHITECT**

NUNES TRABUCCO ARCHITECTS 109 HIGHLAND AVENUE NEEDHAM, MA 02494 781-455-9980

#### LANDSCAPE ARCHITECT


MICHAEL D'ANGELO LANDSCAPE ARCHITECTURE LLC 732 EAST BROADWAY, SUITE #3 BOSTON, MA 02127 203-592-4788

PREPARED FOR / APPLICANT:

SAYED HALABI

ISSUED FOR:

#### PERMITTING PURPOSES



DATE: **APRIL 15, 2020** 

SCALE: 1" = 20'

DESIGNED: DRAFTED: CHECKED: KMR KMR FWK

PROJECT TITLE:

OJECT TITLE:

PERMIT SITE PLAN

1363 - 1365 MAIN STREET WALPOLE, MASSACHUSETTS 02081

SITE DEMO & EROSION AND SEDIMENT

**CONTROL PLAN** 

SHEET:
4 OF 10
PROJECT NO.:

**CE-04** 

#### **GENERAL PERFORMANCE STANDARDS**

- . THE CONTRACTOR SHALL INSTALL, ROUTINELY INSPECT AND MAINTAIN ALL SEDIMENT AND EROSION CONTROLS SUCH THAT THEY ARE IN PROPER WORKING ORDER AT ALL TIMES DURING THE CONSTRUCTION PROJECT UNTIL SUCH TIME AS ALL AREAS OF THE SITE TRIBUTARY TO THOSE EROSION CONTROLS ARE IN A PERMANENTLY STABILIZED
- .. THE CONTRACTOR SHALL MANAGE THE SITE SUCH THAT EROSION AND SEDIMENT FROM RUNOFF AND WIND BLOWN DUST ARE CONTROLLED AND MINIMIZED AT ALL TIMES. THE EROSION CONTROLS SHOWN ON THIS PLAN INCLUDE THE INITIAL SETUP OF EROSION CONTROLS AND BASIC INFORMATION. TO MEET THE REQUIREMENT OF BEST MANAGEMENT PRACTICES. THE CONTRACTOR MUST MANAGE THE SITE PROPERLY WHICH MAY INCLUDE, BUT NOT BE LIMITED TO: MINIMIZING AREAS OF EXPOSED SOILS; INSTALLING TEMPORARY COVER; MAKE NECESSARY ADJUSTMENTS TO THE EROSION AND SEDIMENT CONTROL INSTALLATIONS TO IMPROVE FUNCTION; INSTALL ADDITIONAL EROSION CONTROL WHERE NECESSARY.
- THE EROSION CONTROL WORK SHOWN ON THIS PLAN MAY BE SUBJECT TO OTHER STATE AND LOCAL APPROVALS. THE CONTRACTOR SHALL BE RESPONSIBLE FOR COMPLIANCE WITH THE CONDITIONS AND REQUIREMENTS OF THOSE PERMITS. . DESIGN, INSTALLATION AND MAINTENANCE OF SEDIMENT AND EROSION CONTROLS SHALL BE IN ACCORDANCE WITH BEST MANAGEMENT PRACTICES FOLLOWING THE GUIDELINES INCLUED IN THE FOLLOWING:
- "STORMWATER MANAGEMENT FOR CONSTRUCTION ACTIVITIES, DEVELOPING POLLUTION PREVENTION PLANS AND BEST MANAGEMENT PRACTICES" U.S. ENVIRONMENTAL PROTECTION AGENCY, OCTOBER 1992.
- "MASSACHUSETTS EROSION AND SEDIMENT CONTROL GUIDELINES FOR URBAN AND SUBURBAN AREAS, A GUIDE FOR PLANNERS, DESIGNERS AND MUNICIPAL OFFICIALS", MASS. EXECUTIVE OFFICE OF ENVIRONMENTAL AFFAIRS, MAY 2003.
- U.S.D.A. NATURAL RESOURCES AND CONSEVATION SERVICES (NRCS) GUIDELINES.

#### FEDERAL NPDES PHASE II COMPLIANCE

1. THIS PROJECT IS <u>NOT</u> SUBJECT TO THE FEDERAL CLEAN WATER ACT REQUIREMENTS FOR CONSTRUCTION SITES ADMINISTERED BY THE U.S. ENVIRONMENTAL PROTECTION AGENCY (EPA). THE PREPARATION OF A COMPLETE "STORMWATER POLLUTION PREVENTION PLAN" (SWPPP) AND FILING A NOTICE OF INTENT WITH THE EPA IS NOT

## PERIMETER SEDIMENT BARRIER AND LIMIT OF WORK

- PRIOR TO ANY DISTURBANCE OR ALTERATIONS OF ANY AREA ON THE SITE. A SEDIMENT BARRIER SHALL BE INSTALLED IN THE LOCATIONS SHOWN ON THE PLAN
- 2. INSTALL THE SEDIMENT BARRIER AS SHOWN ON THE PLAN. IN THOSE AREAS WHERE THE TOPOGRAPHY INDICATES THAT STORMWATER RUNOFF WILL BE CONCENTRATED (AT LOW POINTS), ADDITIONAL SEDIMENT BARRIER (SILT FENCE OR EQUAL) SHALL BE STAKED ON THE UPGRADIENT SIDE FOR ADDED FILTRATION AND PROTECTION. THE REQUIRED LOCATIONS FOR THE ADDITIONAL SEDIMENT BARRIER INSTALLATION WILL BE SELECTED BY THE ENGINEER AND / OR THE AUTHORIZED INSPECTOR UPON COMPLETION OF THE SEDIMENT BARRIER INSTALLATION. SEE DETAILS.
- ONCE INSTALLED, THE SEDIMENT BARRIER SHALL BE MAINTAINED IN PLACE UNTIL ALL AREAS UPGRADIENT FROM THE BARRIERS HAVE BEEN PERMANENTLY STABILIZED. 4. ALL DISTURBED AREAS NOT OTHERWISE DEVELOPED OR WHERE SPECIAL STABILIZATION MEASURES OR LANDSCAPE PLANTINGS ARE PROPOSED SHALL BE LOAMED AND SEEDED OR SODDED. SIX INCHES OF LOAM TOPSOIL (MIN. COMPACTED DEPTH) SHALL

BE APPLIED UNLESS, OTHERWISE SPECIFIED. SEE LANDSCAPE PLAN AND OTHER PLANS

AS APPLICABLE 5. THE SEDIMENT BARRIER IS ALSO A LIMIT OF WORK. ALL AREAS OUTSIDE THE LIMIT ARE TO BE LEFT UNDISTURBED. DURING THE SITE WORK. ALL PERSONS AND EQUIPMENT SHALL STAY OUT OF THESE AREAS TO PRESERVE THE EXISTING VEGETATION AND SOIL COVER.

# **CONSTRUCTION ENTRANCE**

- 1. AT THE START OF SITE WORK, A STONE CONSTRUCTION ENTRANCE SHALL BE INSTALLED AT THE ACCESS TO THE SITE FROM THE ROADWAY TO CONTROL THE TRACKING OF MUD OFF THE SITE. THE ENTRANCE SHALL BE MAINTAINED UNTIL THE SITE IS IN A STABILIZED CONDITION WHEN THE POSSIBILITY OF VEHICLES TRACKING
- MUD OFF SITE HAS BEEN ELIMINATED. 2. THE CONTRACTOR SHALL RELOCATE THE CONSTRUCTION ENTRANCE AS THE LOCATIONS
- CHANGE THROUGHOUT THE DURATION OF CONSTRUCTION. 3. THE CONTRACTOR SHALL SWEEP THE ADJACENT ROADWAYS WHEN MUD, DUST, DIRT, DEBRIS, ETC. HAS SHOWN SIGNS OF BUILDUP ON THE ROADWAYS AT THE ENTRANCE OF THE SITE. THE CONTRACTOR SHALL PAY PARTICULAR ATTENTION TO THIS MATTER AND IMMEDIATE ATTENTION IS ALWAYS REQUIRED.

## **DEWATERING OF EXCAVATIONS**

- DISCHARGE FROM DEWATERING PUMPS OR TEMPORARY TRENCH OR EXCAVATION DRAINS SHALL NOT BE DISCHARGED DIRECTLY TO ANY DRAINAGE SYSTEMS OR WETLAND AREA. DISCHARGES SHALL BE DIRECTED TO A TREATMENT SYSTEM CONSISTING OF A SEDIMENT BASIN, STRAW BALE SEDIMENT BASIN, FILTER BAG SYSTEM OR OTHER APPROVED METHOD TO FILTER THE DISCHARGE WATER AND PREVENT EROSION
- 2. ALL DEWATERING DRAINAGE ASSOCIATED WITH CONSTRUCTION ACTIVITIES MUST FIRST OBTAIN ANY APPLICABLE DEWATERING DRAINAGE PERMIT. SUCH DISCHARGES SHALL COMPLY WITH THE MUNICIPAL REQUIREMENTS, UNITED STATES ENVIRONMENTAL PROTECTION AGENCY, MASSACHUSETTS DEP AND OTHER APPROPRIATE AGENCIES.
- UNDER NO CIRCUMSTANCE SHALL DEWATERING DRAINAGE BE DISCHARGED INTO A SANITARY SEWER.

# SOIL STOCKPILES

- 1. STOCKPILES OF SOIL MATERIALS SHALL BE SURROUNDED BY PROPER SILT FENCING, FIBER LOGS, OR STAKED STRAW BALES.
- 2. STOCKPILES THAT ARE TO BE IN PLACE FOR EXTENDED PERIODS OF TIME (MORE
- THAN 30 DAYS) SHALL BE COVERED OR OTHERWISE TEMPORARILY STABILIZED IN ACCORDANCE WITH BEST MANAGEMENT PRACTICES.

## **CATCH BASIN INLET PROTECTION**


CATCH BASINS WITHIN THE WORK AREA OR THAT WILL RECEIVE RUNOFF FROM THE WORK AREA SHALL BE PROTECTED WITH A SILT SACK AND OR OTHER APPROVED INSTALLATION TO MINIMIZE THE SEDIMENT LOAD TO THE BASIN.

#### **DUST CONTROL**

- THE CONTRACTOR SHALL TAKE APPROPRIATE MEASURES DURING SITE WORK TO MINIMIZE WIND BLOWN DUST FROM EXPOSED SOIL SURFACES. MEASURES INCLUDE BUT ARE NOT LIMITED TO:
- SPRINKLING WATER ON EXPOSED SURFACES
- APPLICATION OF TEMPORARY COVER SUCH AS HYDRO MULCH AND TACIFIER, STRAW MATTING, JUTE NETTING ETC.


## SUBSURFACE INFILTRATION SYSTEM PROTECTION

STORMWATER FROM THE DISTURBED CONSTRUCTION SITE SHALL NOT BE DISCHARGED INTO ANY EXISTING OR PROPOSED INFILTRATION SYSTEM(S) UNTIL THE AREA BEING DRAINED IS FULLY STABILIZED AND CLEAN. UNTIL THEN, THE INFILTRATION SYSTEM(S) SHALL REMAIN OFF-LINE AND PROTECTED. THE CONTRACTOR SHALL PROVIDE TEMPORARY BY-PASS SYSTEMS AS NECESSARY TO PREVENT CONSTRUCTION SITE RUNOFF FROM ENTERING THE INFILTRATION SYSTEM(S).



- 1. LAY THE FIBER LOG AT THE UPHILL BASE OF THE SILT FENCE.
- 2. INSTALL APPROXIMATELY 4-6 WOOD STAKES THROUGH THE TWINE/NETTING ALONG THE FIBER LOG AS NEEDED TO HOLD THE LOG IN PLACE.
- 3. DRIVE THE STAKE INTO THE GROUND DEEP ENOUGH TO HOLD THE LOG.
- 4. IN PAVED AREAS, SECURE FIBER LOG WITH CONCRETE BLOCKS OR SAND BAGS.
- 5. THE FILLING OF THE FIBER LOG MAY BE SHREADED STRAW, COIR, COMPOST OR OTHER APPROVED
- 6. FIBER LOG SHALL BE 12 INCHES (MIN) IN DIAMETER UNLESS OTHERWISE NOTED ON THE PLANS.


SEDIMENT CONTROL BARRIER (FIBER LOG)





## CONSTRUCTION SPECIFICATIONS:

- 1. STONE SIZE USE 1  $\frac{1}{2}$ " TO 3  $\frac{1}{2}$ " WASHED, ANGULAR STONE. (SEE SPECIFICATIONS)
- 2. THICKNESS NOT LESS THAN SIX (6) INCHES.
- 3. WIDTH FIFTEEN (15) FEET MINIMUM, BUT NOT LESS THAN THE FULL WIDTH AT POINTS WHERE INGRESS OR EGRESS OCCURS.
- 4. FILTER FABRIC SHALL BE PLACED OVER THE ENTIRE AREA PRIOR TO PLACING OF STONE. USE MIRAFI HP-370 OR EQUAL.
- 5. MAINTENANCE THE ENTRANCE SHALL BE MAINTAINED IN A CONDITION WHICH SHALL PREVENT TRACKING OR FLOWING OF SEDIMENT ONTO PUBLIC RIGHTS-OF-WAY. THIS MAY REQUIRE PERIODIC TOP DRESSING WITH ADDITIONAL STONE AS CONDITIONS DEMAND AND REPAIR OR CLEANOUT OF ANY MEASURES USED TO TRAP SEDIMENT. ALL SEDIMENT SPILLED, DROPPED, WASHED OR TRACKED ONTO PUBLIC RIGHTS-OF WAY MUST BE REMOVED
- 6. PERIODIC INSPECTION AND NEEDED MAINTENANCE SHALL BE PROVIDED.

STONE TRACKING PAD (CONSTRUCTION ENTRANCE) (NO SCALE)








NOTE: NUMBER OF BALES MAY VARY DEPENDING ON SITE CONDITIONS

#### PLAN VIEW DEWATERING OF EXCAVATIONS NOTES:

1. DISCHARGE FROM DEWATERING PUMPS OR TEMPORARY TRENCH OR EXCAVATION DRAINS SHALL NOT DISCHARGE DIRECTLY TO EXISTING DRAIN SYSTEMS. THE DISCHARGES SHALL BE DIRECTED INTO A CONSTRUCTED SEDIMENT BASIN OR A STRAW BALE SETTLING BASIN.

STRAW BALE SETTLING BASIN

(NO SCALE)



Framingham **Boston** • Worcester

1071 Worcester Road Framingham, MA 01701 508-879-0030

www.DGTassociates.com

#### **ARCHITECT**

NUNES TRABUCCO ARCHITECTS 109 HIGHLAND AVENUE NEEDHAM, MA 02494 781-455-9980

#### LANDSCAPE ARCHITECT


MICHAEL D'ANGELO LANDSCAPE ARCHITECTURE LLC 732 EAST BROADWAY, SUITE #3 BOSTON, MA 02127 203-592-4788

PREPARED FOR / APPLICANT:

SAYED HALABI

ISSUED FOR:

PERMITTING PURPOSES



DATE: **APRIL 15, 2020** 

SCALE: **AS NOTED** 

CHECKED: DRAFTED: PROJECT TITLE:

> **PERMIT SITE PLAN**


1363 - 1365 MAIN STREET **WALPOLE, MASSACHUSETTS 02081** 


**EROSION AND SEDIMENT CONTROL NOTES AND DETAILS** 


PROJECT NO.


25551

**CE-05** 











# PRECAST CONCRETE CURB


(NO SCALE)




NOTES: 1. MANHOLE CONNECTION TO PIPE SHALL BE BY MEANS OF A FLEXIBLE RUBBER SLEEVE OR MORTAR. PROJECT PIPE 1"-3" INTO MANHOLE.

DRAIN MANHOLE DETAIL (NO SCALE)





GRANITE CURB (TYPE VA-4)



# NOTE: LENGTH OF TRANSITION MAY NEED TO BE LONGER THAN 6 FEET IN CERTAIN SITUATIONS TO MEET ADA AND MAAB REQUIREMENTS. CONTRACTOR SHALL DETERMINE THE REQUIRED LENGTH TO MEET GRADES AS REQUIRED.

TRANSITIONAL CURB


(NO SCALE)

DEEP SUMP CATCH BASIN

(NO SCALE)

- 1. CURB INSTALLATION ALONG EXISTING ROAD PAVEMENT SHALL BE SAW CUT AND PATCHED WITH A 2½" BITUMINOUS GRADE BINDER COURSE, AND TOPPED WITH A 1-1/2" WEAR COURSE OF TYPE "I". THE CUT JOINT SHALL BE THOROUGHLY SEALED WITH ASPHALT EMULSION AND SAND. TOP OF CURB SHALL BE 6" ABOVE GUTTER GRADE.
- 2. AT ALL LOCATIONS WHERE GRANITE CURBING IS PROPOSED, INCLUDING REPLACEMENT, THE CURB IS TO BE SET IN 6" THICK CONTINUOUS ZERO SLUMP CONCRETE.
- 3. GRANITE CURB INSTALLATION TO BE PER MHD SECTION 501 AND THE LATEST MUNICIPAL STANDARDS.
- 4. CONCRETE TO BE AIR ENTRAINED CLASS D CONFORMING TO MHD M4.02.00.
- 5. GROUTING OF CURB JOINTS TO BE NON-SHRINK GROUTING CONFORMING TO ASTM C-827.

GRANITE CURB (NO SCALE)



- 1. COMPACTED PAVEMENT BASE TO CONFORM TO MASS. HIGHWAY DEPT. SPEC. M 2.01.7.
- COMPACTED COMMON BORROW. NO STONES LARGER THAN 6 INCHES. 3. BITUMINOUS CONCRETE SHALL BE CLASS 1, TYPE 1-1. 4. AT AREAS OF LEDGE/BEDROCK, REMOVE LEDGE TO A DEPTH OF 18 INCHES MINIMUM BELOW
- 5. COMPACTED PAVEMENT BASE TO EXTEND 12 INCHES MINIMUM BEYOND THE EDGE OF PAVEMENT.

BITUMINOUS CONCRETE PAVEMENT

(NO SCALE)

**■ DGT Associates** Surveying & Engineering

> Framingham **Boston** • Worcester

1071 Worcester Road Framingham, MA 01701 508-879-0030

www.DGTassociates.com

#### **ARCHITECT**

NUNES TRABUCCO ARCHITECTS 109 HIGHLAND AVENUE NEEDHAM, MA 02494 781-455-9980

#### LANDSCAPE ARCHITECT


MICHAEL D'ANGELO LANDSCAPE ARCHITECTURE LLC 732 EAST BROADWAY, SUITE #3 BOSTON, MA 02127 203-592-4788

PREPARED FOR / APPLICANT:

SAYED HALABI

ISSUED FOR:

#### PERMITTING PURPOSES



DATE: **APRIL 15, 2020** 

SCALE: **AS NOTED** 

DRAFTED: CHECKED: DESIGNED: **FWK** 

PROJECT TITLE:

# **PERMIT SITE PLAN**


1363 - 1365 MAIN STREET **WALPOLE, MASSACHUSETTS 02081** 


SHEET TITLE:

**SITEWORK DETAILS #2** 

7 OF 10 PROJECT NO. 25551

**CE-07** 







#### NOTES:

- 1. TRENCH BACKFILL SHALL CONFORM TO THE FOLLOWING SPECIFICATIONS AS CONTAINED IN MASSACHUSETTS HIGHWAY DEPARTMENT; <u>STANDARDS</u> AND SPECIFICATIONS FOR HIGHWAYS AND BRIDGES.
- 2. SAND BACKFILL FOR FORCE MAIN BEDDING SHALL CONFORM WITH M1.04.0 TYPE B 'SAND BORROW".
- 3. SELECT BACKFILL SHALL BE ON—SITE SOIL OR IMPORTED BACKFILL CONFORMING WITH M.1.02.0 (a) "SPECIAL BORROW" WITH NO STONES LARGER THAN 3 INCHES.
- 4. ORDINARY BACKFILL SHALL CONSIST OF ON-SITE OR IMPORTED BACKFILL MEETING M1.01.0 WITH NO STONES LARGER THAN 6 INCHES.

# TYPICAL FORCE MAIN BEDDING DETAIL

(NO SCALE)





(NO SCALE)

26" CAST IRON DRAIN MANHOLE ---

-COVER SHALL BE CHECKERED

WITH THREE (3) INCH LETTERS

HEAVY DUTY H-20 LOADING

FINISHED GRADE EL.=SEE PLAN

\_2" SDR-21 PVC "TEE-WYE"

WITH THREADED CAP (TYP.)

GASKETED FOR WATER TIGHT

-EXTERIOR CONCRETE SURFACES

COAL TAR BASED EPOXY PAINT

WATERPROOFED WITH TWO COATS OF

-2" KOR-N-SEAL

FLEXIBLE SLEEVE

2" SDR-21 PVC FORCE MAIN

6" MIN. OF 3/4"-1 1/2" WASHED COMPACTED STONE

SUPPORT BLOCKS (TYP)

--- CONCRETE & MORTAR

4' DIA.

-STAINLESS

STEEL TIE

STRAPS (TYP)

FORCE MAIN CLEANOUT MANHOLE

(NO SCALE)

12" O.C.

(SEE INSTALLATION DETAIL)

2" KOR-N-SEAL-

PRECAST CONCRETE

FLEXIBLE SLEEVE

BASE SECTION

2" SDR-21 PVC FORCE MAIN 2

JOINTS SHALL BE SEALED WITH KENT-

SEAL GASKET PER MUNICIPAL STANDARDS

FRAME & COVER (24" OPENING)

STORMWATER TREATMENT UNIT (STU) FOR STU #1

(NO SCALE)

1071 Worcester Road Framingham, MA 01701 508-879-0030 www.DGTassociates.com

**■ DGT Associates** 

Surveying &

Engineering

Framingham
Boston • Worcester

ARCHITECT

NUNES TRABUCCO ARCHITECTS 109 HIGHLAND AVENUE NEEDHAM, MA 02494 781-455-9980

LANDSCAPE ARCHITECT


MICHAEL D'ANGELO LANDSCAPE ARCHITECTURE LLC 732 EAST BROADWAY, SUITE #3 BOSTON, MA 02127 203-592-4788

PREPARED FOR / APPLICANT:

SAYED HALABI

ISSUED FOR:

PERMITTING PURPOSES



DATE: **APRIL 15, 2020** 

SCALE: AS NOTED

DESIGNED: DRAFTED: CHECKED: KMR KMR FWK

PROJECT TITLE:

PERMIT SITE PLAN

1363 - 1365 MAIN STREET WALPOLE, MASSACHUSETTS 02081

SHEET TITLE:


SITEWORK DETAILS #3

SHEET: 8 OF 10 PROJECT NO.:

25551

**CE-08** 

#### (2) 2-INCH BALL VALVES-2" SDR-21 PVC FORCE MAIN 30" DIAMETER CAST IRON ACCESS COVER-H-20 LOADING MIN. JUNCTION BOX 5% SLOPE ON BOTTOM OF-CHAMBER FLOOR TOWARDS PUMPS PROPOSED PRECAST REINFORCED-CONCRETE PUMP CHAMBER 72" DIA. MANHOLE 2.0 HP SUBMERSIBLE MECHANICAL FLOAT SWITCHES-ÈFFLUENT PUMPS 6" HDPE INLET " (SHOWN WITH TOP REMOVED)



# NOTE: AT THIS TIME, THE DESIGN DETAILS OF THE PUMP STATION ARE SHOWN AS APPROXIMATE. FINAL DESIGN OF PUMPS, FLOAT ELEVATIONS, ETC. TO BE COORDINATED FOR THE FINAL CONSTRUCTION DOCUMENTS. THE NOTES BELOW ARE TO DESCRIBE THE INTENT OF THE DESIGN.

(1) GENERAL:

(A) FURNISH AND INSTALL ONE COMPLETE PUMPING SYSTEM CONSISTING OF TWO SUBMERSIBLE EFFLUENT PUMPS AND MOTORS, DISCHARGE PIPING AND VALVES, MECHANICAL FLOAT SWITCH LEVEL CONTROLS, HIGH WATER ALARM, DUPLEX CONTROL PANEL AND A PRECAST CONCRETE DOSING CHAMBER.

(B) ALL EQUIPMENT SHALL BE INSTALLED IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS AND WARRANTED FOR A PERIOD OF AT LEAST ONE YEAR.

(C) UPON COMPLETION OF THE INSTALLATION, THE CONTRACTOR SHALL PROVIDE A SUFFICIENT QUANTITY OF CLEAN WATER TO CONDUCT TWO PUMP OPERATION TESTS FOR EACH PUMP UNDER THE DIRECTION AND SUPERVISION OF THE DESIGN ENGINEER.

(2) PUMP CHAMBER:

(A) PUMP CHAMBER SHALL BE A 72" INSIDE DIAMETER PRECAST CONCRETE

STRUCTURE.

(B) CONSTRUCTION JOINTS AND OPENINGS SHALL BE SEALED WITH HYDRAULIC CEMENT, OR OTHERWISE MADE WATERTIGHT. THE EXTERIOR SURFACES SHALL BE WATERPROOFED WITH TWO COATS OF A COAL TAR BASED EPOXY PAINT, OR APPROVED EQUAL.

(C) PUMP CHAMBER IS TO BE PRESSURE TESTED PER ASTM C-1227.
 (D) ONE (1) 30-INCH DIAMETER OPENING SHALL BE CAST TOP AS LOCATED ON THE PLAN. THIS 30-INCH OPENING SHALL HAVE ONE 30-INCH DIAMETER BOLTED CAST IRON MANHOLE FRAME AND COVER SET IN THE FLAT TOP. THIS COVER SHALL HAVE A GASKETED SEAL TO MAKE THE COVER AND WATERTIGHT.

(3) PUMPS AND MOTORS:

(A) THE PUMPS AND MOTORS SHALL BE A HEAVY DUTY EFFLUENT—TYPE PUMPS
WITH A MINIMUM 2—INCH DISCHARGE. THE PUMPS AND MOTORS SHALL BE FULLY
SUBMERSIBLE AND SHALL OPERATE AT \_\_\_\_\_ RPM WITH A 200v, THREE PHASE AC
POWER SOURCE. THE ELECTRICAL CONTRACTOR SHALL VERIFY THAT THE PROPER
VOLTAGE IS AVAILABLE AT THE CONTROL PANEL.

(B) USE TWO \_\_\_\_\_\_ EFFLUENT PUMPS, OR AN EQUIVALENT
APPROVED BY THE ENGINEER. THE PUMP SHALL BE RATED AS FOLLOWS:

A) HORSEPOWER: \_\_\_\_

B) \_\_\_ GALLONS PER MINUTE

C) \_\_\_ FEET, TOTAL DYNAMIC HEAD

(4) LEVEL CONTROLS:

(A) SEALED FLOAT—TYPE MECHANICAL SWITCHES SHALL BE SUPPLIED TO CONTROL THE SUMP LEVEL, ALARM SIGNAL, AND LAG PUMP ON. TWO FLOAT SWITCHES SHALL BE USED TO CONTROL THE SUMP LEVEL; ONE FOR PUMP "OFF" AND ONE FOR PUMP "ON". A THIRD SWITCH SHALL BE PROVIDED TO CONTROL THE LAG PUMP ON IN THE EVENT THAT THE LEAD PUMP DOES NOT OPERATE. A FOURTH SWITCH SHALL BE PROVIDED WITH A POWER SOURCE SEPARATE FROM THE PUMP POWER AND SHALL BE FOR THE ALARM UNIT. A NEMA—4 JUNCTION BOX FOR THE FLOAT SWITCHES SHALL BE INSTALLED

ABOVE THE HIGH WATER LEVEL.

(B) THE FLOAT LEVEL CONTROLS SHALL BE SET TO OPERATE AT THE ELEVATIONS INDICATED ON THE PLANS.

(5) CONTROL PANEL:

(A) THE DUPLEX CONTROL PANEL SHALL BE EQUIPPED WITH A RUN LIGHT FOR EACH PUMP, PROPERLY SIZED CIRCUIT BREAKERS, A TRANSFORMER TO GIVE PROPER VOLTAGE TO THE CONTROL CIRCUITS AND ONE THREE—WAY PUMP CONTROL SWITCH. THE SWITCH POSITIONS ARE AS FOLLOWS: 1) MANUAL PUMP ON, 2) PUMP OFF, 3) AUTOMATIC.

(B) AN ALTERNATOR RELAY SHALL BE PROVIDED IN THE DUPLEX CONTROL PANEL TO ALTERNATE THE OPERATION OF THE PUMPS EACH TIME THE "PUMP ON" SWITCH IS ACTIVATED.

(C) THE DUPLEX CONTROL PANEL SHALL BE FOR A 200v, THREE PHASE AC POWER SUPPLY AND HOUSED IN A NEMA-4 ENCLOSURE. THE PANEL SHALL BE INSTALLED IN THE LOCATION SHOWN ON THE ELECTRICAL DRAWINGS.

(6) ALARM:

(A) A HIGH WATER ALARM SHALL BE SUPPLIED WITH BOTH AN AUDIBLE AND VISUAL ALARM WITH A POWER SUPPLY SEPARATE FROM THE PUMP. THE ALARM SHALL BE MOUNTED IN A NEMA-4 ENCLOSURE. AN ALARM SILENCER BUTTON SHALL BE PROVIDED TO SILENCE THE AUDIBLE ALARM WHILE THE VISUAL REMAINS ILLUMINATED UNTIL MANUALLY RESET. THIS AUDIBLE AND VISUAL ALARM SHALL BE LOCATED ADJACENT TO THE CONTROL PANEL.

(7) PIPING:
(A) THE PUMP STATION DISCHARGE PIPING AND FITTINGS SHALL BE 2—INCH SCH—40 PVC WITHIN THE PUMP CHAMBER TO INCLUDE THE FOLLOWING FOR EACH PUMP: IN THE VERTICAL POSITION: A 2—INCH BALL—TYPE CHECK VALVE; IN THE HORIZONTAL POSITION: A 2—INCH QUICK DISCONNECT UNION. PIPING AND VALVES SHALL BE ARRANGED SO THAT THEY ARE EASILY

ACCESSIBLE FROM THE PUMP CHAMBER ACCESS COVER.

(B) THE FORCE MAIN PIPING SHALL BE 2-INCH SDR-21 PVC PIPE WITH BELL AND SPIGOT JOINTS, AND SHALL BE LAID AS SHOWN IN THE BEDDING DETAIL. THE FORCE MAIN SHALL DISCHARGE INTO THE PRESSURE DISTRIBUTION MANIFOLD. THE FORCE MAIN PIPING INSTALLATION SHALL BE DEMONSTRATED TO BE WATER TIGHT BY PRESSURE TESTING MAINTAINED FOR TWO (2) HOURS.

(C) ALL PIPING OUTSIDE THE PUMP CHAMBER WHICH IS LESS THAN FOUR (4) FEET BELOW FINISHED GRADE SHALL BE SURROUNDED WITH A MINIMUM OF TWO-INCHES OF RIGID STYROFOAM INSULATION.

(8) DOSING REQUIREMENTS:

(A) THE SYSTEM HAS BEEN DESIGNED TO PROVIDE DOSES EQUAL TO \_\_\_\_ GALLONS

PER DOSE.

(B) ADDITIONAL STORAGE PROVIDED IN THE PUMP STATION, ABOVE THE HIGH


WATER ALARM LEVEL IS APPROXIMATELY \_\_\_\_ GALLONS. IN THE EVENT OF A

POWER FAILURE, THIS IS SUFFICIENT CAPACITY TO PROVIDE FOR \_\_\_ HOURS

OF STORAGE.

# DRAINAGE PUMP STATION DETAIL & DUPLEX PUMP SYSTEM & PUMP STATION SPECIFICATIONS

(NO SCALE)



# RECHARGER #1 DETAIL

(NO SCALE)

# DGT Associates Surveying & Engineering

Framingham Boston • Worcester

1071 Worcester Road Framingham, MA 01701 508-879-0030

www.DGTassociates.com

#### **ARCHITECT**

NUNES TRABUCCO ARCHITECTS 109 HIGHLAND AVENUE NEEDHAM, MA 02494 781-455-9980

#### LANDSCAPE ARCHITECT


MICHAEL D'ANGELO LANDSCAPE ARCHITECTURE LLC 732 EAST BROADWAY, SUITE #3 BOSTON, MA 02127 203-592-4788

PREPARED FOR / APPLICANT:

SAYED HALABI

ISSUED FOR:

#### PERMITTING PURPOSES



DATE: **APRIL 15, 2020** 

SCALE: AS NOTED

DESIGNED: DRAFTED: CHECKED: KMR KMR FWK
PROJECT TITLE:

# PERMIT SITE PLAN


1363 - 1365 MAIN STREET WALPOLE, MASSACHUSETTS 02081


SHEET TITLE:


SITEWORK DETAILS #4

SHEET: 9 OF 10 PROJECT NO.: 25551


**CE-09** 








# SEWER CLEANOUT (NO SCALE)




(NO SCALE)



TYPICAL THRUST BLOCK

(NO SCALE)



(NO SCALE)

MICHAEL D'ANGELO LANDSCAPE ARCHITECTURE LLC 732 EAST BROADWAY, SUITE #3 BOSTON, MA 02127 203-592-4788 PREPARED FOR / APPLICANT: **SAYED HALABI** ISSUED FOR: PERMITTING PURPOSES NO. APP DATE DESCRIPTION DATE: **APRIL 15, 2020** SCALE: **AS NOTED** DRAFTED: PROJECT TITLE: **PERMIT SITE PLAN** 1363 - 1365 MAIN STREET WALPOLE, MASSACHUSETTS 02081 SHEET TITLE: **SITEWORK DETAILS #5 CE-10** PROJECT NO .: 25551

CHECKED:

**DGT Associates** 

Surveying &

Engineering

Framingham **Boston** • Worcester

1071 Worcester Road Framingham, MA 01701 508-879-0030

www.DGTassociates.com

NUNES TRABUCCO ARCHITECTS

LANDSCAPE ARCHITECT

109 HIGHLAND AVENUE NEEDHAM, MA 02494


ARCHITECT

781-455-9980

 $\Box$ 

SHEET 1


plot date: 4/3/2020



LANDSCAPE PLANTING AND LIGHTING PLAN

MA/M

STRFFT



#### PLANTING:

- 1. DURING CONSTRUCTION, PROTECT ALL EXISTING SITE FEATURES, STRUCTURES AND UTILITIES.
- 2. PLANTS SHALL BE TRUE TO SPECIES AND VARIETY SPECIFIED AND NURSERY GROWN IN ACCORDANCE WITH THE AMERICAN STANDARD FOR NURSERY STOCK UNDER CLIMATIC CONDITIONS SIMILAR TO THOSE IN THE LOCALITY OF THE PROJECT. SUBSTITUTIONS WILL BE PERMITTED ONLY IF APPROVED BY THE LANDSCAPE ARCHITECT.
- 3. LANDSCAPE ARCHITECT APPROVAL IS REQUIRED BEFORE PLANT MATERIAL IS PURCHASED. LANDSCAPE ARCHITECT RESERVES THE RIGHT TO SEE ALL MATERIAL IN PERSON AT THE NURSERY. IF TRAVEL OUTSIDE OF MA IS REQUIRED, LANDSCAPE ARCHITECT'S TRAVEL COSTS SHALL BE PAID FOR BY THE CONTRACTOR.
- 4. ALL EXPOSED BURLAP, WIRE BASKETS AND OTHER MATERIALS ATTACHED TO PLANTS SHALL BE REMOVED PRIOR TO PLANTING. CARE SHALL BE TAKEN NOT TO DISTURB THE ROOT BALL OF PLANTS.
- 5. THOROUGHLY WATER ALL PLANTS IMMEDIATELY AFTER PLANTING.
- 6. WHERE DISCREPANCIES IN QUANTITIES OCCUR, DRAWINGS SUPERCEDE PLANT NOTES AND SCHEDULE.
- 7. TRANSPLANTING SHALL BE DONE IN ACCORDANCE WITH THE AMERICAN STANDARD FOR NURSERY STOCK. 8. LOAM USED IN PLANT BEDS SHALL BE UNIFORM IN COMPOSITION, FREE FROM SUBSOIL, STONES LARGER THAN 1", NOXIOUS SEEDS
- AND SUITABLE FOR THE SUPPORT OF VEGETATIVE GROWTH. THE pH VALUE SHALL BE BETWEEN 5.5 AND 6.5. 9. MULCH IN TREE AND SHRUB BEDS SHALL BE NATURAL, NATIVE HEMLOCK MULCH FREE OF GROWTH OR GERMINATION INHIBITING INGREDIENTS. SUBMIT SAMPLES FOR APPROVAL.
- 10.LOCATIONS FOR PLANTS AND/OR OUTLINE OF AREAS TO BE PLANTED ARE TO BE STAKED OUT AT THE SITE FOR APPROVAL BY THE LANDSCAPE ARCHITECT.
- 11. SOIL DEPTHS: a.) SHRUBS AND PERENNIAL BEDS: 18" MIN.; b.) GROUNDCOVER: 6" MIN.; c.) TREES: SEE DETAIL; d.) SOD/SEED: 6"MIN. 12. PROVIDE A SUBSURFACE ROOTBALL ANCHOR BY PLATIPUS EARTH ANCHORS, SIZE FOR CALIPER


#### **IRRIGATION DIAGRAM NOTES:**

- 1. IRRIGATION IS DESIGN-BUILD INSTALLATION. CONTRACTOR SHALL SUBMIT SHOP DRAWINGS FOR FINAL LAYOUT OF IRRIGATION SHOWING LOCATIONS AND SIZES OF MAIN LINES AND LATERAL LINES, ZONES, RAIN AND SOIL SENSORS, AND CUT SHEETS FOR CONTROLLER SYSTEM AND COMPONENTS. INCLUDE ANY NECESSARY SLEEVING.
- 2. IRRIGATION CONTRACTOR SHALL VERIFY PSI/GPM REQUIREMENTS AT THE SITE BEFORE STARTING CONSTRUCTION.
- 3. TREES SHOULD BE ON A SEPARATE ZONE.
- 4. PROVIDE A REMOTE RAIN SENSOR ON A ROOF AREA THAT IS NOT OBSTRUCTED FROM THE OPEN SKY.
- 5. COORDINATE WITH OWNER FOR POINT OF CONNECTION LOCATION.
- 6. COORDINATE WITH OWNER FOR IRRIGATION CONTROLLER LOCATION.
- 7. INSTALL DRIP TUBING, .6GPH, 12" CENTERS, STAKED EVERY TURN OR EVERY 4' 8. COORDINATE WITH OWNER FOR BACKFLOW PREVENTION LOCATION.
- 9. INSTALLER SHALL INSTALL LIGHTNING AND SURGE PROTECTION DEVICES THROUGHOUT SYSTEM AS PER MANUFACTURER'S HIGHEST SPECIFICATION LEVELS.
- 10.INSTALLER SHALL ADHERE TO ALL MANUFACTURER'S SPECIFICATIONS RELATED TO CONTROL SYSTEM INSTALLATION.
- 11.INSTALLER SHALL INSTALL MOISTURE SENSORS. CONTRACTOR SHALL INSTALL PER MANUFACTURERS'S SPECIFICATIONS AND SHALL BE RESPONSIBLE TO PROGRAM RELATED HYDROZONES TO RESPECTIVE SOIL MOISTURE SENSORS. PROVIDE ONE FOR EACH IRRIGATION ZONE WITH AUTOMATIC SHUT-OFF ONCE MOISTURE REQUIREMENTS ARE MET.
- 12.PRIOR TO BID, CONTRACTOR TO VERIFY THAT ALL MATERIALS, INSTALLATION PARAMETERS, AND OPERATIONS CONFORM TO ALL APPLICABLE CODES AND ORDINANCES. NO LATER THAN FIVE DAYS BEFORE BID SUBMITTALS CONTRACTOR SHALL NOTIFY DESIGNER AND OWNER OF ANY CHANGES REQUIRED DUE TO CURRENT CODE OR ORDINANCE DISCREPANCIES.

SYMBOL	QTY.	LATIN NAME	COMMON NAME	SIZE	NOTES
TREES	•	•	•		
AR	5	ACER RUBRUM 'OCTOBER GLORY'	RED MAPLE	3"-3.5" CAL.	B&B, 6' CLEAR BRANCHING
QC	1	QUERCUS COCCINEA	SCARLET OAK	3" - 3.5" CAL.	B&B, 6' CLEAR BRANCHING
TP	9	THUJA PLICATA 'GREEN GIANT'	GREEN GIANT ARBORVITAE	8' TALL	B&B
TO	34	THUJA OCCIDENTALLIS 'EMERALD'	EMERALD ARBORVITAE	5' TALL	B&B
PA	5	PICEA ABIES	NORWAY SPRUCE	8' TALL	B&B
SHRUBS A	AND GROUP	IDCOVER			
IS	11	ILEX 'STEEDS'	STEEDS HOLLY	3' TALL	36" O.C. B&B
IG	7	ILEX GLABRA 'SHAMROCK'	SHAMROCK INKBERRY	3' TALL	36" O.C. B&B
TH	41	TAXUS X MEDIA 'HICKSII'	HICKS YEW	3' TALL	30" O.C. B&B
RA	39	RHUS 'GRO LOW'	GROW LOW SUMAC	3 GAL	36" O.C. B&B
PERENNIA	ALS AND OR	NAMENTAL GRASSES			
AC	13	ASTILBE CHINENSIS 'PURPURKERZE'	PURPLE CANDLE	1 GAL	18" O.C.; CONTAINER
CK	28	CALAMAGROSTIS X A. 'KARL FOERSTER'	FEATHER REED GRASS	1 GAL	24" O.C. CONTAINER
RF	28	RUDBECKIA FULGIDA 'GOLDSTURM'	BLACK EYE SUSAN	1 GAL	18" O.C. CONTAINER
PL	16	PEROVSKIA A. 'LITTLE SPIRE'	LITTLE SPIRE RUSSIAN SAGE	1 GAL	18" O.C. CONTAINER
PH	23	PENNISETUM A. 'HAMELN'	HAMELN FOUNTAIN GRASS	1 GAL	24" O.C. CONTAINER
PV	96	PANICUM VIRGATUM 'SHENANDOAH'	SWITCH GRASS	1 GAL	24" O.C. CONTAINER
LS	160	LIRIOPE SPICATA	CREEPING LIRIOPE	1 GAL	15" O.C. CONTAINER

SYMBOL	LABEL	DESCRIPTION	ARRANGEMENT	LLF	LUM. LUMENS	REP
	_					ILLUMINATE
<u>-</u>	SL4	RAR1-160L-100-4K7-4W-BC	SINGLE	0.900	11885	617-947-8996 STEVE PRUDHOMME
0	WL-3	LNC3-24L4K-075-3	SINGLE	0.900	5702	ILLUMINATE 617-947-8996 STEVE PRUDHOMME
-	DL-1	WS-W30511-A120914	SINGLE	0.900	642	ILLUMINATE 617-947-8996 STEVE PRUDHOMME

- 1. SUBMIT CUT SHEETS FOR APPROVAL; SEE PHOTOMETRIC PLAN FOR MORE INFORMATION
- 2. COORDINATE ALL BUILDING MOUNTED LIGHT WITH FINAL ARCHITECTURAL DRAWINGS AND
- ELECTRICAL DRAWINGS.
- 3. SEE CIVIL ENGINEER'S DRAWING FOR POLE FOOTING; FOOTING SHOULD BE EXPOSED 2' ABOVE



Luminaire So	chedule					
Symbol	Qty	Label	Arrangement	LLF	Description	Lum. Lumens
+	2	SL-4	SINGLE	0.900	RAR-1-160L-100-4K7-4W-BC	7371
•	1	WL-3	SINGLE	0.900	LNC3-24L4K-075-3	5702
	8	DL-1	SINGLE	0.900	WS-W30511 A120914	642

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
PARKING LOT	Illuminance	Fc	1.34	4.7	0.0	N.A.	N.A.
SIDEWALK	Illuminance	Fc	0.90	4.6	0.0	N.A.	N.A.
SPILL LIGHT	Illuminance	Fc	0.00	0.5	0.0	N.A.	N.A.

Prepared By:






MICHAEL D'ANGELO

732 EAST BROADWAY #: BOSTON, MA 02127

9  $\vdash$  $\mathcal{C}$ 

 $\vdash$ 



REV. NO	. DATE	DESCRIPTION

PHOTOMETRIC PLAN

SHEET 2

t. 203.592.4788

www.m-d-l-a.com

EV. NO. | DATE | DESCRIPTION


LANDSCAPE ANDLIGHTING DETAILS

AS NOTED

plot date: 4/3/2020

FOR PERMIT; NOT FOR CONSTRUCTION

SHEET 3 OF 3



WS-W30507

PRODUCT DESCRIPTION A popular understated design updated with a sleek black finish, Pandora brings sculptural sophistication and high-powered energy-efficient LEDs to your overall lighting scheme, whether you mount it inside or out. With its tiered, minimalist form and two points of illumination, you'll never regret opening this box.

SPECIFICATIONS Construction: Aluminum hardware, glass diffuser Light Source: High output LED Finish: Black, Oil Rubbed Bronze Standards: ETL & cETL listed, Wet Location, IP65

Western Distribution Cente

PLANTING SOIL MIXTURE

UNDISTURBED SUBGRADE

**FEATURES**  Up and down illumination No transformer or driver needed Color Temperature: 3000K Dimmer: ELV • CRI: 85 Rated Life: 50,000 hours

#### ORDER NUMBER


Fax (800) 526.2585

Model		Wattage	Voltage	LED Lumens	Delivered Lumens	Finish		
WS-W30507	7"	12W		270	200			
WS-W30509	9"	20W	120V	546	410	ВК	Black	
WS-W30511	11"	28W		550	415	ORB	Oil Rubbed Bronze	

Exa	mple:	WS-V	v30509-	ORB

1750 Archibald Avenue Ontario, CA 91760 Lithia Springs, GA 30122 Modern Forms retains the right to modify the design of our products at any time as part of the company's continuous improvement program. Feb 2018

Port Washington, NY 11050







HUBBELL Outdoor Lighting

# FEATURES

• Low profile LED area/site luminaire with a variety of IES distributions for lighting applications such as retail, commercial and campus parking lots Featuring Micro Strike Optics which maximizes target zone illumination with

Visual comfort standard

 Compact and lightweight design with low EPA • 3G rated for high vibration applications including bridges and overpasses Control options including photo control, occupancy sensing, NX Distributed Intelligence™ and 7-Pin with networked controls



ELECTRICAL

CONTROLS

over-current protection and short circuit protection with auto recovery

Photo control, occupancy sensor and

 7-pin ANSI C136.41-2013 photocontrol receptacle option available for twist lock

photocontrols or wireless control modules

in fixture wireless control module, features

wireless available for complete

on/off and dimming control

DATE: LOCATION:

TYPE:

CATALOG #:

PROJECT:

# CONTROL TECHNOLOGY SiteSync NX DISTRIBUTED WISCAPE WISCAPE

#### **SPECIFICATIONS**

INSTALLATION

CONSTRUCTION Rectilinear form mimics the traditional shoebox form factor keeping a similar but updated style and appearance, ideal for

retrofit applications Die-cast housing with hidden vertical heat fins that are optimal for heat dissipation while keeping a clean smooth outer surface

 Corrosion resistant, die-cast aluminum housing with powder coat paint finish Entire optical aperture illuminates to create a larger luminous surface area resulting in a low glare appearance without sacrificing optical performance

• 80, 160, 320 or 480 midpower LEDs 3000K, 4000K or 5000K (70 CRI) CCT Zero uplight at 0 degrees of tilt Field rotatable optics

degree adjustable increments. (Restrictions

apply for 7-pin options)

(control accessories sold separately) Standard square arm mount, compatible with B3 drill pattern 0-10V dimming leads available for use with control devices (provided by others, must specify lead length) Optional universal mounting block for ease of installation during retrofit applications. Available as an option or accessory for SiteSync™ wireless control system is available via 7-pin See ordering information and details square and round poles. at: www.hubbelllighting.com/sitesync Knuckle arm fitter option available for 2-3/8" OD tenon. Max tilt of 60 degrees with 4 NX Distributed Intelligence<sup>™</sup> available with

CONTROLS (CONT'D) Universal 120-277 VAC or 347-480 VAC input voltage, 50/60 Hz wiSCAPE® available with in fixture wireless control module, features dimming and • Ambient operating temperature -40°C to 40°C occupancy sensor via 7-pin

 Drivers have greater than 90% power factor and less than 20% THD CERTIFICATIONS • DLC® (DesignLights Consortium Qualified, · LED drivers have output power over-voltage, with some Premium Qualified configurations. Please refer to the DLC website for specific product qualifications at www.designlights.org Field replaceable surge protection device provides 20kA protection meeting ANSI/ IEEE C62.41.2 Category C High and Surge Location Category C3; Automatically takes Listed to UL1598 and CSA C22.2#250.0-24 for wet locations and 40°C ambient temperatures fixture off-line for protection when device • 3G rated for ANSI C136.31 high

vibration applications

 Fixture is IP66 rated Meets IDA recommendations using 3K CCT configuration at 0 degrees of tilt 5 year limited warranty


 See <u>HLI Standard Warranty</u> for additional information

KEY DATA	
Lumen Range	3,000-32,000
Wattage Range	25–227
Efficacy Range (LPW)	118–155
Fixture Projected Life (Hours)	L70>238K
Weights lbs. (kg)	13.5–24 (6.1–10.9)

dimming and occupancy sensor











# SPECIFICATIONS CONSTRUCTION appearance outdoor environments IV distributions reduced glare with 70 CRI INSTALLATION junction box) Page 1/5 Rev. 11/19/19 LNC3LED-SPEC

















1391 MAIN STREET WALPOLE, MASS.

> SEPTEMBER 4, 2019 PHONE: (617)357-9740 www.feldmansurveyors.com



RESEARCH DK FIELD CHIEF SH PROJ MGR MJG APPROVED SHEET NO. 1 OF 1 CADD DK FIELD CHECKED JOB NO. 17005 FILENAME: S:\PROJECTS\17000s\17005\DWG\SUBMITTED\17005-EC(SUBMIT2020-01-02).dwg

MARK J. GUERARD JR., PLS (MA# 51815) MGUERARD@FELDMANSURVEYORS.COM